



KERONE

A CRISIL-NSIC RATED COMPANY
ISO-9001-2008 COMPANY



AIMCAL (USA)
(EUROPE)



A.M.P.E.R.E


In Association With




Kerone Research & Development Centre (KRDC)

B/47, Addl. MIDC. Anand Nagar, Ambernath (East), Thane- 421 506, India

Tel- +91-251-2620542/13/44/45/46, Email-info@kerone.com, www.kerone.com



**Batch Microwave Heat Treatment for
Sterilization of Caralluma Powder**





Kerone Research & Development Centre (KRDC)

B/47, Addl. MIDC. Anand Nagar, Ambernath (East), Thane- 421 506, India

Tel- +91-251-2620542/13/44/45/46, Email-info@kerone.com, www.kerone.com


Customer:	
Process:	Batch Microwave Heat Treatment for Sterilization of Caralluma Powder

Test Report No: 237/KRDC/LAB/17 Mum 04/10/2023

Date Sample reception : 08/07/2023
 ID : KRDC/R&D/23-24/04/10

Sample Description:

Sampling : As Requested
 Sample Condition : Acceptable
 Sampling date : 04/10/2023
 Requirement : Sterilization of Caralluma Powder (03 Drums)
 Start Date test : 04/10/2023
 End Date test : 04/10/2023

Laboratory Experimental System -**System Specifications -**

The value obtained is already corrected for possible recover value stated, if applicable. This document may not be reproduced or disclosed wholly or partly in any part thereof without the written consent of the laboratory management or customer. This document relates only to the specimen samples processed. The processed sample will be kept in this laboratory for 7 days from the date of heat treatment.



Kerone Research & Development Centre (KRDC)

B/47, Addl. MIDC. Anand Nagar, Ambernath (East), Thane- 421 506, India

Tel- +91-251-2620542/13/44/45/46, Email-info@kerone.com, www.kerone.com

Microwave Power	3.5 KW (CW)
Frequency	2450 MHz \pm 50
Convective Power	3.5 KW (airflow 350 I/min at 20°C)
Microwave Exposure Zone (Cavity)	1 Cubic meter
Mode Stirrer	One
Thermal Monitoring System	Single Channel Fiber Optic: Range - 40 to 250°C
Exhaust Power	1 HP
Tray size (width*height*depth)	450*950*50 mm

Laboratory's Environmental Conditions –

Temperature (degree C)	29.4°C (\pm 5°C)
Humidity (%)	\leq 50% RH
Pressure (kN/m² or kPa)	Not recorded

Note for recommendation: Environmental conditions have a direct impact on test results. Accuracy and consistency of test data are affected by the laboratory conditions






Kerone Research & Development Centre (KRDC)

B/47, Addl. MIDC. Anand Nagar, Ambernath (East), Thane- 421 506, India

Tel- +91-251-2620542/13/44/45/46, Email-info@kerone.com, www.kerone.com

Equipment Used -

Name of Equipment	Picture of Equipment	Specifications
Compact Thermal Imaging Camera		Model: FLIR E-30 Resolution: 160x 120IR Thermal sensitivity of 0.10°C
Thermo Hygrometer		Model No: HTC-2 Temperature accuracy: $\pm^{\circ}\text{C}$ (1.8°F) Temperature resolution: 0.1°C (0.2°F) Humidity range: 10%~99% RH Humidity accuracy: $\pm 5\%$ RH Humidity resolution: 1% RH
Moisture Analyzer		Make: Axis Balance Description: Moisture range: 1%(sample 0.02/0.05g), 0.1% (Sample 0.5/5g), 0.01%(Sample>5g)

Procedure of the Experiment -

- The experiment was performed on Caralluma powders to speed up the heating rate.
- For this experimental run, the given sample was placed in the MW heating system with suitable parameters.
- After the heating treatment, the sample was analyzed.



Kerone Research & Development Centre (KRDC)

B/47, Addl. MIDC. Anand Nagar, Ambernath (East), Thane- 421 506, India

Tel- +91-251-2620542/13/44/45/46, Email-info@kerone.com, www.kerone.com

Analytical Results:**Trial 1 (AP-03)**

Cycle	Sample Wt. (kgs.)	Cycle Time (mins.)	Specifications of Microwave	Remark
1	28.200	After 10 mins	Magnetron Power: 3.5 kW; Set temp: 80°C	Warming up the drum On product temp: (30-32) °C
2	28.200	After 20 mins.	Magnetron Power: 3.5kW; Set temp: 80°C	Heating Continuous On product temp: (35-39) °C
3	28.200	After 30 mins.	Magnetron Power: 3.5 kW; Set temp: 80°C	Heating Continuous On product temp: (42-47)°C
4	28.200	After 40 mins.	Magnetron Power: 3.5 kW; Set temp: 80°C	Heating Continuous On product temp: (52-65)°C
5	28.200	After 50 mins.	Magnetron Power: 3.5 kW; Set temp: 80°C	Heating Continuous On product temp: (70-75)°C
6	28.200	After 60 mins.	Magnetron Power: 3.5 kW; Set temp: 80°C	Temperature achieved as desired On product temp: (80-84)°C

Trial 2 (AE-07)

Cycle	Sample Wt. (kgs.)	Cycle Time (mins.)	Specifications of Microwave	Remark
1	27.120	After 10 mins	Magnetron Power: 3.5 kW; Set temp: 80°C	Warming up the drum On product temp: (30-41) °C
2	27.120	After 20 mins.	Magnetron Power: 3.5kW; Set temp: 80°C	Heating Continuous On product temp: (44-50) °C
3	27.120	After 30 mins.	Magnetron Power: 3.5 kW; Set temp: 80°C	Heating Continuous On product temp: (53-59)°C
4	27.120	After 40 mins.	Magnetron Power: 3.5 kW; Set temp: 80°C	Heating Continuous On product temp: (60-68)°C
5	27.120	After 50 mins.	Magnetron Power: 3.5 kW; Set temp: 80°C	Heating Continuous On product temp: (70-78)°C
6	27.120	After 60 mins.	Magnetron Power: 3.5 kW; Set temp: 80°C	Temperature achieved as desired On product temp: (78-81)°C

Format: F/R&D/01

The value obtained is already corrected for possible recover value stated, if applicable. This document may not be reproduced or disclosed wholly or partly in any part thereof without the written consent of the laboratory management or customer. This document relates only to the specimen samples processed. The processed sample will be kept in this laboratory for 7 days from the date of heat treatment.



Kerone Research & Development Centre (KRDC)

B/47, Addl. MIDC. Anand Nagar, Ambernath (East), Thane- 421 506, India

Tel- +91-251-2620542/13/44/45/46, Email-info@kerone.com, www.kerone.com

Trial 3 (BE-08)

Cycle	Sample Wt. (kgs.)	Cycle Time (mins.)	Specifications of Microwave	Remark
1	28.200	After 10 mins	Magnetron Power: 3.5 kW; Set temp: 80°C	Warming up the drum On product temp: (30-35) °C
2	28.200	After 20 mins.	Magnetron Power: 3.5kW; Set temp: 80°C	Heating Continuous On product temp: (40-43) °C
3	28.200	After 30 mins.	Magnetron Power: 3.5 kW; Set temp: 80°C	Heating Continuous On product temp: (49-53)°C
4	28.200	After 40 mins.	Magnetron Power: 3.5 kW; Set temp: 80°C	Heating Continuous On product temp: (55-60)°C
5	28.200	After 50 mins.	Magnetron Power: 3.5 kW; Set temp: 80°C	Heating Continuous On product temp: (63-69)°C
6	28.200	After 60 mins.	Magnetron Power: 3.5 kW; Set temp: 80°C	Temperature achieved as desired On product temp: (74-80)°C


Trials Images: (Treated Samples):**Trial 1 (AP-03)****Trial 2 (AE-07)**



Kerone Research & Development Centre (KRDC)

B/47, Addl. MIDC. Anand Nagar, Ambernath (East), Thane- 421 506, India

Tel- +91-251-2620542/13/44/45/46, Email-info@kerone.com, www.kerone.com


**Trial 3 (BE-08)****Thermal images:**



Kerone Research & Development Centre (KRDC)

B/47, Addl. MIDC. Anand Nagar, Ambernath (East), Thane- 421 506, India

Tel- +91-251-2620542/13/44/45/46, Email-info@kerone.com, www.kerone.com

**Observations:**

The heating behavior of Caralluma Powder was investigated under the Microwave heating system. The heating rate was found to be increasing with respect to increasing in time. As per the physical investigation, it was observed that the sterilization of the product for up to 87°C drum temperature was achieved without any Deformation of the drum and was seal packed during treatment. Sterilization of the product for 60 minutes was achieved with condensation and no charring effect.

Mrs. Priya Tayde**(Tested By)**